

Subsection 1.1.5. *Qualification and Responsibilities of Persons Performing Tests, Inspections and Maintenance of Fire Protection Equipment*

- 1.1.5.1.** The requirements of this Subsection come into force on the 21st day of November, 1999.
- 1.1.5.2.** Any person performing tests, inspections and maintenance of fire alarm systems, with or without voice communication capability, shall be responsible for complying with the requirements of Articles 1.1.5.3. and 1.1.5.4.
- 1.1.5.3.(1)** Any person who performs the annual tests or annual inspections of a fire alarm system required under Article 6.3.2.2. and any person who repairs, replaces or alters components of a fire alarm system shall:
- (a) have successfully completed a program or course acceptable to the Fire Marshal,
 - (b) produce for inspection, upon request by the owner or the Chief Fire Official, a copy of a certificate or document attesting to the successful completion of a program or course referenced in Clause (a), and
 - (c) perform the inspection, test, repair, replacement or alteration in accordance with Article 6.3.1.8. and Subsection 6.3.2.
- (2)** Despite Sentence (1), a person who has not successfully completed the required program or course may perform the work described in Clause (1)(c) provided that:
- (a) the work is done under the supervision of a person who has successfully completed a program or course required by Clause (1)(a),
 - (b) no more than two persons work under the supervision of the person referred to in Clause (a), and
 - (c) the supervision is provided at the work site.
- (3)** Any person supervising another as permitted in Sentence (2) shall:
- (a) advise the owner in writing that the work has been completed in accordance with Article 6.3.1.8. and Subsection 6.3.2., and
 - (b) be deemed to be the person referred to in Article 1.1.5.4.
- 1.1.5.4.** Despite Article 1.1.1.1., any person who performs the annual tests or annual inspections of a fire alarm system required by Article 6.3.2.2. and any person who repairs, replaces or alters components of a fire alarm system shall be responsible for carrying out the provisions of Article 1.1.5.3.